# **Installation and Instruction Manual**

## **Bluetooth Switch - ON/OFF Control**

### 1. Technical Specifications

Product type	Bluetooth Switch	
Mains voltage	220~240VAC 50Hz	
Rated load	400VA(Capacitive); 800W(Resistive)	
Stand-by power	<0.5W	
Operation frequency	2.4 GHz - 2.483 GHz	
Transmission power	4 dBm	
Range (Typical)	10 ~ 30m	
Protocol	Bluetooth 5.0 SIG Mesh	
Operation temperature	Ta: -20°C ~ +45°C	
Case temperature (Max.)	Tc: +75°C	
Storage temperature	-20°C ~ +60°C	
Max. relative humidity	20 ~ 90%	
IP rating	IP20	
Impulse withstand voltage	2.5KV	
Duty type	S1	
Insulation material	PTI material group Illa	
Glow wire	Level 3, 850°C	
Protection	Built-in protection provided	
Type of switch	Single load(single-ploe disconnection)	
Insulation	Class II	


### 4. Installation

▲ Warnings: 1. Installation must be carried out by a qualified engineer in accordance with local regulations. 2. Disconnect power supply before installing.

HYTRONIK

**HBTD8200S** 


3. Ensure environmental conditions are suitable for electronic equipment






Free App for set-up and commissioning






Typical Switch Box Mounting



Wire Preparation





4. Dimming Interface Operation Notes

Switch-Dim

NO

The provided Switch-Dim interface allows for a simple dimming method using commercially available non-latching (momentary) wall switches. Detailed Push switch configurations can be set on Koolmesh app.

L' N S1 S2

 $\otimes$ 

-This product should be installed by a qualified electrician.

Switch Function	Action	Descriptions	
	Short press (<1 second) * Short press has to be longer than 0.1s, or it will be invalid.	- Turn on/off - Recall a scene - Turn on only - Quit manual mode - Turn off only - Do nothing	
Push switch	Double push	- Turn on only - Quit manual mode - Turn off only - Do nothing - Recall a scene	
	Long press (≥1 second)	- Dimming - Colour tuning - Do nothing	
Sensor-link (VFC signal only)	/	<ul> <li>Upgrade a normal on/off motion sensor to a Bluetooth controlled motion sensor</li> </ul>	
Emergency Self-Test Function	Short press (<1 second) * Short press has to be longer than 0.1s, or it will be invalid.	- Start Self test (Monthly) - Start Self test (Annually - Stop Self test - Invalid	
	Long press (≥1 second)	- Start Self test (Monthly) - Start Self test (Annually - Stop Self test - Invalid	
Fire Alarm (VFC signal only)	Refer to <b>Koolmesh</b> <sup>*</sup> App User Manual V2.1	<ul> <li>Able to connect the Fire Alarm system</li> <li>Once the fire alarm system is triggered, all the lumina controlled by the Push Switch will enter the preset so (normally it's full on), after the fire alarm system gives the ena signal, all the luminaries controlled by this Push Switch will re back to normal status.</li> </ul>	

#### 5. Additional Information / Documents

1.To learn more about detailed product features/functions, please refer to www.hytronik.com/download ->knowledge ->Introduction of App Scenes and Product Functions

2. Regarding precautions for Bluetooth Product installation and operation, please kindly refer to www.hytronik.com/download ->knowledge ->Bluetooth Products - Precautions for Product Installation and Operation

3. Data sheet is subject to change without notice. Please always refer to the most recent release on www.hytronik.com/products/bluetooth technology ->Bluetooth Dimmers

4. Regarding Hytronik standard guarantee policy, please refer to www.hytronik.com/download ->knowledge ->Hytronik Standard Guarantee Policy

WWW.HYTRONIK.COM

Subject to change without notice.



Subject to change without notice

HBTD8200S-20230718-A2

HYTRONIK

HBTD8200S-20230718-A2